

Top View (covers removed)

NOTES:

- 1. Conforms to IAPMO standard Z1000-2013.
- 2. Polypok Pipe seals used for inlet and outlet penetrations.
- 3. Tank is H2O Rated.
- 4. 6' of maximum Earth Cover.
- 5. Provide bedding of 3/8" rock min of 4" thick for tank or redwood stringers laid long-ways for tank to sit on.
- 6. Excavation requirements to be minimum of 18" all around tank to allow for repairs if needed.
- 7. All measurements are in inches.
- 8. Trelleborg pipe seals provided at 42" opening. Please see attached document.

MODEL NUMBER: 4500GST-T WEIGHT: 54,000lbs

^{*} for more information, please contact Code Precast. Design subject to change.